



LIQUID CAPACITY (GALLONS)	DIM A	DIM B	DIM C	DIM D	DIM E
320	3'-0"	7'-0"	4'-6"	3'-7"	3'-4"
500	4'-0"	6'-0"	5'-10"	4'-10"	4'-7"
750	4'-0"	8'-1"	6'-3"	5'-0"	4'-9"
1000	5'-1"	8'-2"	6'-3"	5'-0"	4'-9"
1200	5'-9"	8'-6"	6'-6"	5'-0"	4'-9"
1500	5'-7"	10'-8"	6'-3"	5'-0"	4'-9"
2000	4'-11"	15'-11"	6'-0"	5'-0"	4'-9"
2500	5'-9"	16'-10"	6'-0"	5'-0"	4'-9"
3000	5'-9"	16'-10"	6'-9"	5'-9"	5'-6"
4000	7'-8"	16'-7"	6'-9"	5'-6"	5'-3"
5000	7'-8"	16'-7"	7'-11"	6'-9"	6'-6"

NOTES:

- 1) DESIGN LOAD: H-20 TRAFFIC WITH DRY SOIL CONDITIONS (WATER LEVEL BELOW TANK.)
- 2) BEDDING NOTE: SUITABLE SUB-BASE BEDDED WITH GRANULAR MATERIAL SHALL BE PREPARED TO HANDLE ANTICIPATED LOADS.
- 3) ALL INTERCEPTORS SHALL MEET THESE STANDARDS OR APPROVED EQUAL.

WEST BAY
SANITARY DISTRICT

GREASE INTERCEPTOR

APPROVED BY:

/S/ - SERGIO RAMIREZ
GENERAL MANAGER

06-28-23
DATE: